WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101161
Permit No.
Basin 104

NOTICE OF INTENT NO. 58050

1. OWNER Ruby Mchenry
MAILING ADDRESS 3949 Ponderosa Drive
Carson City, NV 89701

ADDRESS AT WELL LOCATION ~~3949~~ Ponderosa Drive,
carson City, NV. 3949

2. LOCATION SW 1/4 SE 1/4 Sec. 29 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
009-143-11 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 94' of 1-1/4" drop pipe and pump from well. Measured depth of well at 100' and static water level at 60'. Installed 2" tremme pipe and blew out fill to a depth of 103' where we had solid bottom. We then installed Mills Knife and perforated 4 rows per foot from 80' back to surface. We then installed 105' of 2" tremme pipe, mixed 58 bags of Portland Type II cement with 300 gallons of water and pumped in cement from bottom of well to surface.				

Date started 6/8/2006 , 19__
Date completed 6/8/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 109' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	+1	109'

Perforations:
Type perforation Mills Knife
Size perforation
From 80' feet to surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 109'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Tranger
By driller performing actual drilling on-site or contractor
Date 7/5/2006

USE ADDITIONAL SHEETS IF NECESSARY