WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101171
Permit No.
Basin 102

NOTICE OF INTENT NO. 52873

1. OWNER Robert Arndell
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2785 8th ST

2. LOCATION NE ¼ SE ¼ Sec. 17 T. 17 N/S R 25 E Lyon County
PERMIT NO. Issued by Water Resources | 17-344-4407 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	35	35'
Hard Clay		35	62	32'
Sticky Clay		62	100	38'
Black Clay-Lrg Sand		100	130	30'
Brown Clay		130	145	15'
Clay Gravel		145	180	35'
Small Gravel		180	195	15'
Lrg Gravel		195	220	25'

RECEIVED
OCT 04 2005
STATE ENGINEER'S OFFICE

Date started 7-8, 2005
Date completed 7-8, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188"	+1	20
6 5/8		SDR 21	20	220

Perforations:
Type perforation Grinder cut
Size perforation 1/8"
From 200 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC. Contractor
Address P.O. Box 1255 Carson City, NV 89702 Contractor

Nevada contractor's license number issued by the State Contractor's Board 46497
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2134
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-10-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

2005 JUN 25 PM 2:15