WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101182
Permit No.
Basin 051

NOTICE OF INTENT NO. 55286

1. OWNER FREHNER CONSTRUCTION
MAILING ADDRESS 522 OSINO #8
ELKO, NV 89801

ADDRESS AT WELL LOCATION STATE RD 766
3.3 MILES N OF CARLIN, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 9 T 33N N/S R 52 E ELKO County
PERMIT NO. C-239 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE CONST.
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL		0	6	6
CEMENTED SAND		6	38	32
BROWN CLAY		38	141	103
HARD BLACK ROCK		141	199	58
HARD RED ROCK		199	225	26
HARD BLACK ROCK		225	274	49
FRACTURED BLACK ROCK	x	274	295	21

Date started 5/2/06, 19__
Date completed 5/16/06, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	400		3

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	295	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.5		250	+2	295

Perforations:
Type perforation TORCH CUT
Size perforation 1/8 x 3
From 140 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 295 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. DBA FERTIG DRILL Contractor
Address P.O. BOX 525 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1584
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6-21-06

USE ADDITIONAL SHEETS IF NECESSARY