WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101199
Permit No.
Basin 93

NOTICE OF INTENT NO. 51672

1. OWNER KIM MONAHAN
MAILING ADDRESS 25 Owens Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
25 Owens Road
Reno, Nevada 89506

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) ~~079-480-40~~ 079-481-61 (Parcel No.) Antelope Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	6	5
Medium to coarse sands w/clay streaks		6	18	12
Brown sandy clays		18	23	5
Cemented decomposed granite sands		23	28	5
Brown sandy clays		28	41	13
Soft zone		41	43	2
Brown sandy clays		43	127	84
Brown medium sand soft		127	136	9
Brown sandy clays		136	141	5
Soft zone		141	146	5
Brown sandy clays		146	170	24
Soft zone	X	170	199	29
Brown sandy clays		199	217	18
Weathered granite		217	235	18
Fracture soft	X	235	241	6
Weathered granite		241	250	9

Date started December 8, 2003, 19
Date completed December 12, 2003, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22+		

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	250 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 185 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)

Date December 15, 2003

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627