WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101211
Permit No.
Basin 108

NOTICE OF INTENT NO. No NoI

1. OWNER KENNETH MILLER
MAILING ADDRESS #9 SUNSET HILLS
ADDRESS AT WELL LOCATION 9 - Sunset Hills Dr Mason Valley Lyon

2. LOCATION ~~SW~~ SE ¼ ~~SE~~ SW ¼ Sec. 32 T. 14 N N/S R. 25 E. County
PERMIT NO. Issued by Water Resources | Parcel No. 014-242-04 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Sand		4	6	2
Sticky Clay		6	162	
BASALT LAVAL SPAVEL		162	164	2
Got Very sand at 164			166	2

Date started 3.15.06, 20
Date completed 3.25.06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
16	FROM	126 FT.
so I INSTALLED 10 GPM		
pump SET AT 147 FT.		

8. WELL CONSTRUCTION
Depth Drilled 166 Feet Depth Cased 166 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	54 Feet
6 Inches	54 Feet	166 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	166

Perforations:
Type perforation TORCH CDT.
Size perforation 8 ROW 3/3 - 3/32
From 158 feet to 162 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5 to 52
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Very good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Clifford Thompson
Contractor
Address #1 MANHA LN. YERINGTON
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0023772
Nevada driller's license number issued by the Division of Water Resources, the on site driller 855
Signed Clifford Thompson
By driller performing actual drilling on site or contractor
Date 6.26.06.

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627