

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 35541 ✓

1. OWNER DAVID ITZA ADDRESS AT WELL LOCATION 495 - 22ND ST. BATTLE MTN
 MAILING ADDRESS P.O. Box 578
BATTLE MTN NV 89220
 2. LOCATION S 1/4 SW 1/4 Sec. 34 T. 32 N/S R. 44 E HANDEEN County
 PERMIT NO. 11-040-59 Parcel No. 1st Subdivision Well # 44
 Issued by Water Resources Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	20	20
SANDY CLAY		20	40	20
CLAY		40	50	10
SANDY CLAY		50	70	20
CLAY		70	75	5
BROWN CLAY SAND	yes	75	95	20

8. WELL CONSTRUCTION
 Diameter hole 10 1/8 inches Total depth 95 feet
 Casing record T1-95
 Weight per foot _____ Thickness 3/16
 Diameter _____ From _____ To _____
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 ft feet
 Gravel packed: Yes No
 Gravel packed from 70 feet to 95 feet
 Perforations:
 Type perforation SAMED
 Size perforation 5 X 2
 From 75 feet to 95 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality Good

Date started 10-10 1905
 Date completed 10-12 1905

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LBJ Drilling Co. Contractor
 Address P.O. Box 709 Womca 89446 Contractor
 Nevada contractor's license number 9605
 Nevada contractor's drillers number _____
 Nevada driller's license number 12070 Actual Driller
 Signed [Signature] Contractor
 Date 10-13-05

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>20</u>		<u>3</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours



STATE ENGINEERS OFFICE

2006 FEB -6 PM 1:20

RECEIVED

STATE ENGINEERS OFFICE

2005 DEC -5 PM 1:55

RECEIVED