

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 35540 ✓

1. OWNER **DAVID ITKA** ADDRESS AT WELL LOCATION **420 KAYCI AVE, BATTLE MTN**
 MAILING ADDRESS **P.O. Box 578**
BATTLE MTN, NV 89820

2. LOCATION **SE 1/4 SW 1/4 Sec 24 T. 32 N/S.R. 44 E Lander** County
 PERMIT NO. **11-040-58** Parcel No. **JSF Subdivision Well #5** Subdivision Name

3. TYPE OF WORK: New Well Recondition Deepen Other

4. PROPOSED USE: Domestic Irrigation Industrial Municipal Test Stock

5. TYPE WELL: Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	20	20
SANDY CLAY		20	35	15
CLAY		35	50	15
SANDY CLAY		50	65	15
CLAY		65	80	15
BRICK CLAY + SAND	yes	80	110	30

8. WELL CONSTRUCTION

Diameter hole **10 7/8** inches Total depth **110** feet
 Casing record **7 1/2 - 110**
 Weight per foot _____ Thickness **1.89**

6 7/8 Diameter From **7 1/2** feet To **110** feet
 _____ inches _____ feet _____ feet

Surface seal: Yes No Type **Cement**
 Depth of seal **50 ft** feet
 Gravel packed: Yes No
 Gravel packed from **85** feet to **110** feet

Perforations:
 Type perforation **Sawed**
 Size perforation **1/2 x 2**
 From **75** feet to **95** feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level **35** feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality **Good**

Date started **10-13** 19**05**
 Date completed **10-15** 19**05**

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	30	UKK	3

BAILER TEST

G.P.M.	Draw down	feet	hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **L B D Drilling Co.** Contractor
 Address **P.O. Box 902 Wmca 89446** Contractor
 Nevada contractor's license number **9605**
 Nevada contractor's drillers number _____
 Nevada driller's license number **78070** Actual Driller
 Signed **Joe B...** Contractor
 Date **10-23-05**



STATE ENGINEERS OFFICE

2006 FEB -6 PM 1:20

RECEIVED

STATE ENGINEERS OFFICE

2005 DEC -5 PM 1:55

RECEIVED