COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101226
Permit No.
Basin 103

NOTICE OF INTENT NO. 56752

1. OWNER SCOTT SNELLING CONSTRUCTION
MAILING ADDRESS 318 SYDNEY LN
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 6965 IRON MTN BLVD
STAGECOACH, NV 89429

2. LOCATION ~~NE~~ SW ¼ ~~NE~~ SW ¼ Sec ~~12~~ 7 T 17 N R ~~22~~ 23 E LYON County
PERMIT NO. (Issued by Water Resources) 015-324-10 (Parcel No) IRON MOUNTAIN (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE GRAVELS		0	5	5
VOLCANIS GRAVELS		5	28	23
COURSE GRAVELS		28	160	132
VOLCANIC SANDS				
BROWN CLAY		160	182	22
SOFT SANDS CLAY		182	192	10
FRACTURED GRAVELS	XX	192	240	48

GPS INFO:
39.34726*N
119.44918*W
NAD 83

Date started 6/28, 20 06
Date completed 7/2, 20 06

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	35	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	2.16	20	240

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 240 feet

9. WATER LEVEL
Static water level 158 feet below land surface
Artesian flow G.P.M 17 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 7/16/06