COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101233
Permit No.
Basin 105

NOTICE OF INTENT NO. 58211

1. OWNER PHILIP AND BETTY PINDER
MAILING ADDRESS 1062 LOG CABIN
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1062 LOG CABIN
GARDNERVILLE, NV 89410

2. LOCATION NE ¼ ~~NE~~ ¼ Sec 12 T 12 N R 20 E DOUGLAS County

PERMIT NO. 5[illegible] (Issued by Water Resources) | 1220-12-710-023 (Parcel No.) | PINENUT RIDGE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL	approx	+2	220	220
6 1/8 bore hole to 298		220	298	78
BROWN CLAY		220	251	31
COURSE DG SANDS	XXX	251	292	41
SMALL GRAVELS				
BLACK SILTY SANDS		292	298	6
GPS INFO:				
38.91523*N				
119.67878*W				
NAD83				

Date started 7/10, 20 06
Date completed 7/11, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	55	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 298 ~~78~~ Feet Depth Cased 298 ~~90~~ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches	220 Feet	298 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.68	.188	208	298

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X3/32
From 258 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 7/18/06