WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101245
Permit No.
Basin 064

NOTICE OF INTENT NO. 56870

1. OWNER NEWMONT MINING CO.
MAILING ADDRESS PO. BOX 388
VALMY NV 89438

ADDRESS AT WELL LOCATION LONE TREE
LTH-03

2. LOCATION NE ¼ NE ¼ Sec. 14 T. 34 N/S R. 44 E. HUMBOLT County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| LITHIC | | 0 | 45 | 45 |
| VALMY QUARTZ | | 45 | 85 | 40 |
| LITHIC | | 85 | 250 | 165 |
| 3/4 PLUG BETWEEN | | 80 | 209 | |

Date started 1-14, 2006
Date completed 1-15, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | 1½ HOURS |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 11¾ Inches | 0 Feet | 10 Feet |
| 6½ Inches | 10 Feet | 250 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | | Schedule 80 | 0 | 250 |

Perforations:
Type perforation SLOT
Size perforation .020
From 200 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 250 feet to 209 feet

9. WATER LEVEL
Static water level 124.4 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature WARM °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND DRILLING CO. (Contractor)
Address 605 UNION PACIFIC WAY (Contractor)
EIKO NV 89801
Nevada contractor's license number issued by the State Contractor's Board 030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2290
Signed (By driller performing actual drilling on site or contractor)
Date 1-15-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

RECEIVED
2006 JAN 26 AM 11:36
STATE ENGINEERS OFFICE

RECEIVED
2006 JUL 26 PM 1:42
STATE ENGINEERS OFFICE

7