WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101248
Permit No.
Basin 104

NOTICE OF INTENT NO. 57404

1. OWNER N.D.O.T.
MAILING ADDRESS 1301 Hot Springs Rd.
Carson City, NV 89706

ADDRESS AT WELL LOCATION 1799 Fairview Dr.

2. LOCATION NE 1/4 SW 1/4 Sec. 21 T 15N N/S R 20 E Carson County
PERMIT NO. (Issued by Water Resources) | Parcel No. 010-061-06 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" x 38' domestic well. This well was contaminated and had no well cap. We used a compressor and blew debris from well until clean. We then perforated from 21' to surface at four around and 2' intervals. We then pumped approximately .5 cu yards of neat cement mixed 5.2 gal/sack using tremie from bottom of well to top. We then cut the top 2 feet of casing off.				
NAD 83				
N39.14974				
W119.74697				

Date started 7/11/2006, 19__
Date completed 7/18/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	38

Perforations:
Type perforation Factory
Size perforation Puncture
From 0 feet to 21 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 7/18/2006

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2006 JUL 26 PM 1:37
STATE ENGINEERS OFFICE