WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

I

OFFICE USE ONLY
Log No. 101311
Permit No.
Basin 107

NOTICE OF INTENT NO. 55-775

1. OWNER Evered J. Mason
MAILING ADDRESS 28499 Nichols Rd Galt CA 95632-8204
ADDRESS AT WELL LOCATION 31 Foothill Rd

2. LOCATION SW ¼ SE ¼ Sec. 20 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | 010-522-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand some Gravels		1	7	
Sand		7	46	
Some Clay layers		46	52	
Silt w/fine Sand		52	63	
Grey Black Clay (w/Silt)		63	87	
Clay		87	96	
Sand, Silt		96	107	
Clay Grey Black		107	125	
Coarse Sand (w/Clay layer DG)		125	139	
Gravels/Clay		139	154	
Clay		154	208	
W some Clay seams				
Gravels		208	218	
Gravels	✓	218	240	

RECEIVED 05 JUN 23 AM 11:17 STATE ENGINEERS OFFICE

Date started 6/7/05, 20
Date completed 6/8/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-25		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 241 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	50' Feet
8 3/4 Inches	50 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1.88	13	1	20
6 5/8	PVC	SDR 21	20	240

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 4 x 5# rows
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 240 feet

9. WATER LEVEL
Static water level 76' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Peach Drilling Inc
Contractor
Address PO 399
Contractor
88 NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed
By driller performing actual drilling on site or contractor
Date 6/8/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627