COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101322
Permit No.
Basin Ø99

NOTICE OF INTENT NO. 57236

1. OWNER Steve Kauffman
MAILING ADDRESS 2626 Starr Meadows Loop
Reno, NV 89509

ADDRESS AT WELL LOCATION
16205 Fetlock Dr.
Reno, NV 89506

2. LOCATION SW ¼ SW ¼ Sec ~~25~~ 03 T ~~03~~ 23 N R 18 E Washoe County

PERMIT NO. N/A (Issued by Water Resources) 078-231-11 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DG and granite boulders | | 0 | 25 | 25 |
| Brown Rock | | 25 | 27 | 2 |
| Grey Clay | | 27 | 50 | 23 |
| Red clay | | 50 | 53 | 3 |
| Red rock | | 53 | 72 | 19 |
| Red clay | | 72 | 75 | 3 |
| Black Rock | | 75 | 83 | 8 |
| Red rock | | 83 | 100 | 17 |
| Grey clay | | 100 | 107 | 7 |
| Lt. brown Rock | | 107 | 125 | 35 |
| Grey clay | | 125 | 140 | 15 |
| Multi-colored Rock | | 140 | 175 | 35 |
| Black Rock | | 175 | 223 | 48 |
| Red Clay | | 223 | 230 | 7 |
| Black Rock | x | 230 | 310 | 80 |
| Granite | xx | 310 | 520 | 210 |

Date started 5-4, 20 06
Date completed 5-13, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx. | 12 | 500 | 12 |

8. WELL CONSTRUCTION

Depth Drilled 520 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 520 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 14 | .188 | -1 | 19 |
| 6 | 5 | .390 | 19 | 520 |

Perforations:
Type perforation Factory
Size perforation .030
From 280 feet to 320 feet
From 460 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50+ ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 520 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow none G.P.M none P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING C0. (CONTRACTOR)
Address P.O. Box 8056 (CONTRACTOR)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 037915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 6-10-06

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. • (214) 340-9429 • FormsOnADisk.com