WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101377
Permit No.
Basin 089

NOTICE OF INTENT NO. 57820

1. OWNER Art & Dawn Banard
MAILING ADDRESS 3680 Pershing Lane
Washoe, NV 89704

ADDRESS AT WELL LOCATION 3680 Pershing Lane

2. LOCATION NW 1/4 SE 1/4 Sec. 6 T 16N N/S R 20E E Washoe County
PERMIT NO. | Issued by Water Resources | 050-464-21 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6" x 65' well by perforating from 45' to 20' with a Mills Knife. We then pumped 1.25 cubic yards of neat cement mixed 5.2 gallons of water per sack. We pumped using tremie pipe from the bottom to the top of the well. Top of well casing is 5' below grade in a vault.				
Washoe County Permit # WL 060171				
NAD 83				
N 39.27956				
W 119.773780				
Possible old log # 7996				
39.29665°N 119.77279°W NAD29 GCUS				

Date started 9/27/2006 , 19__
Date completed 9/27/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	64

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 20 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 9/27/2006

USE ADDITIONAL SHEETS IF NECESSARY

2006 OCT 17 AM 10:07 RECEIVED STATE ENGINEER