WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101445
Permit No.
Basin 002

NOTICE OF INTENT NO. 55038

1. OWNER Claude Edwood Morris
MAILING ADDRESS P.O. Box 207 Denio NV. 89404
ADDRESS AT WELL LOCATION Ashdown Mill

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 45 N/S R. 28 E. Humboldt County
PERMIT NO. NEV-2005-105 (Issued by Water Resources) 02-21-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil	28	0	6	6
sandy gravel		6	50	44

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40	0	40

Perforations:
Type perforation mill slot
Size perforation .010
From 40 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 27 feet to 50 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 590 W Silver St (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2277
Signed (By driller performing actual drilling on site or contractor)
Date 10-29-03

Date started 10-25, 2005
Date completed 10-29, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2006 OCT -2 PM 1:13
STATE ENGINEER'S OFFICE

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

RECEIVED
2006 AUG 31 AM 11:09
STATE ENGINEERS OFFICE