

J's Jones or Electek well

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 101473

Permit No. _____

Basin 833

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44403

1. OWNER John Falan ADDRESS AT WELL LOCATION 8.25 Miles South of SR 140 on Sand Pass Rd
 MAILING ADDRESS P.O. Box 132 Orvada NV 89425

2. LOCATION SW 1/4 NE 1/4 Sec 12 T. 39 S. R. 36 E Humboldt County
 PERMIT NO. 44332 Parcel No. N/A Subdivision Name None
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Mud		0	70	
Drill Threw Cased in Portion of hole @ 70' Brake out @ 85' Drilled Blind no Returns For Entire Depth NOT much Resistance From 85' to 180'				
Set Casing to TD Gravel Pack to Surface Produce hole Gravel Drapper ADDED Gravel & Produce well making Sawd keep Adding Gravel Till Sawd @ Stopper. Casing USED 22 48" SIZES OF Gravel				

RECEIVED
2006 AUG 23 AM 11:11
STATE ENGINEERS OFF

8. WELL CONSTRUCTION
 Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 180' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1.88</u>	<u>150+1</u>	<u>180</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32x4
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 180' feet

9. WATER LEVEL
 Static water level 6.3' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Inc
 Address 10760 Grass Valley Road Winnie, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
 Signed [Signature]
 Date Dec 2 2002

Date started Nov 20 2002
 Date completed Nov 25 2002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>7hr</u>