

Log No. 101508
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57295

1. OWNER West Ridge Homes ADDRESS AT WELL LOCATION 653 APPALOOSA
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SE 1/4 Sec. 24 T. 13 N/S R. 20 E Douglas County
 PERMIT NO. APC-24-701-047 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	6	6
GRAY CLAY		6	30	24
BROWN CLAY-GRAVEL		30	55	25
BROWN DENSE CLAY		55	92	37
MEDIUM GRAVEL		92	113	21
BROWN GRITTY CLAY		113	180	67
MEDIUM GRAVEL		180	220	40

38. 88589° N
 119. 68403° W
 NAD 83

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>.188</u>	<u>71</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 51 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 220 feet

Date started 12 July, 2006
 Date completed 13 July, 2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>		<u>1.5</u>

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dolson
 Date 06 Aug 06

RECEIVED
 2006 AUG 22 PM 2:33
 STATE ENGINEERS OFFICE