STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 101515
Permit No.
Basin Ø44

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58508

1. OWNER Queenstake Resources GW-56
MAILING ADDRESS HC 31, Box 78, Elko, NV 89801

ADDRESS AT WELL LOCATION Queenstake Jerritt Canyon minesite, 55 miles north of Elko, NV.
Subdivision Name: N/A County: Elko

2. LOCATION NW¼NW¼ Sec3T40N/S R54E
PERMIT/WAIVER NO. NDEP # NEV00000200 (Issued by Water Resources) N/A (Parcel. No.)

Latitude 41 23.859 N
Longitude 115 5~~8~~3.083 W
UTM E ☒ NAD 27
N ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & gravel		0	30	30
Gravel & clay		30	65	35
Clay		65	70	5
Gravel & clay		70	90	20
Clay		90	95	5
Gravel & clay		95	160	65

Date started: 08/16, 20 06
Date completed: 08/17, 20 06

RECEIVED 2006 AUG 21 AM 11:13 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 152 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6.50 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.96	0.2118	+2	152

Perforations:
Type of perforation Slotted
Size of perforation 0.200"
From 132 feet to 152 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 10 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 122 to 160 ☐ Pumped ☒ Poured
Type: 3/8" x 1/4"
Bentonite Chips: ☒ Yes ☐ No 10 to 122 ☐ Pumped ☒ Poured
Type: 3/8"

7. Water Level
Static water level: 38 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
13		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (CONTRACTOR)
Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2258
Signed
By driller performing actual drilling on site or contractor
Date 08/18/06

QW