

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 101521
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **58210**

1. OWNER **JACK WHITE CONSTRUCTION** ADDRESS AT WELL LOCATION **1935 TEDSEN LN GARDNERVILLE, NV 89410**
 MAILING ADDRESS **423 CLAIRE CT GARDNERVILLE, NV 89460**

2. LOCATION NE 1/4 SW 1/4 Sec 12 T 12 N R 20 E **DOUGLAS** County

PERMIT NO. NW NE **1220-12-510-012**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
HARDPAN CLAY		0	3	3
COURSE GRAVELS		3	91	88
BROWN CLAY		91	163	72
SMALL SANDS AND GRAVELS		163	259	96
BROWN GUMMY CLAY		259	271	12
FRACTURED GRAVELS	XXX	271	300	29

RECEIVED
 2006 AUG -3 AM 11:08
 STATE ENGINEERS OFFICE

GPS INFO:
 38.92214*N
 119.68254*W NA 83

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
0 Feet 300 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	300

Perforations:
 Type perforation **SAW CUT**
 Size perforation **3X3X32**
 From 260 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 58 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 58 feet to 300 feet

9. WATER LEVEL
 Static water level 163 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 7/11, 20 06
 Date completed 7/13, 20 06

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>60</u>	<u>3 HRS</u>

Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **0055548**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2157**
 Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 7/29/06