WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1015299
Permit No.
Basin 088

NOTICE OF INTENT NO. 57392

1. OWNER Effie Boegle
MAILING ADDRESS P.O. Box 18001
Reno, NV 89511

ADDRESS AT WELL LOCATION 2215 Rhodes Rd.

2. LOCATION SE 1/4 ~~SE~~ NE 1/4 Sec. 4 T 17N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 017-390-14 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 4" x 46' deep well. We Flushed the well with water. We then tremie piped approximately 6 sacks of neat cement from bottom to top displacing the water and mixed 5.2 gal/sack. We then pressure grouted the well with an additional 12 sacks of neat cement. Pressure never exceeded 50 psi and we stopped pumping after 18 sacks.				
Washoe Co. Permit #WL060115				
NAD83				
N39.36935				
W119.73480				

Date started 8/1/2006 , 19__
Date completed 8/1/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 46 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2		.250	0	46

Perforations:
Type perforation ??
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/2/2006

USE ADDITIONAL SHEETS IF NECESSARY