


\* Revised Log \*

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



OFFICE USE ONLY  
Log No. 101533  
Permit No.  
Basin 149

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58404

1. OWNER Stone Cabin Company  
MAILING ADDRESS 3856 SW Sam Sneed Court  
Redmond, OR 97756

ADDRESS AT WELL LOCATION Test Range Rd.

2. LOCATION SE 1/4 NE 1/4 Sec 14 T 01N N/S/R 46 E  
PERMIT/WAIVER No. Issued by Water Resources Parcel No.

Latitude 37 Deg 56.247 UTME NAD 27  
Longitude 116 Deg 47.014 -116. N NAD 83/WGS 84  
Subdivision Name: 783566 County: Nye

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sand/Clay		0	10	10
Gravel/Clay		10	20	10
Gravel/Cobbles		20	110	90
Fine Gravel/Clay		110	115	5
Gravel		115	164	49
Cemented Gravel/Sand		164	170	6
Fine Gravel/Sand		170	180	10
Gravel		180	210	30
Gravel/Clay		210	260	50
Clay		260	270	10
Clay/Sand		270	295	25
Sand/Fine Gravel		295	300	5
Gravel/Some Clay		300	310	10
Clay/Sand		310	337	27
Sand/Gravel		337	350	13
Clay/Sand		350	370	20
Clay		370	375	5
Sand/Clay/Fine Gravel		375	385	10
Clay		385	410	25
Gravel/Some Clay		410	416	6
Clay/Sand		416	430	14
Gravel/Sand		430	450	20
Sand/Clay		450	455	5
Gravel/Sand		455	516	61
Sand/Gravel/Clay		516	530	14
Clay		530	535	5
Sand/Gravel		535	600	65

8. WELL CONSTRUCTION					
Depth Drilled	600	Feet	Depth Cased	0	Feet
HOLE DIAMETER (BIT SIZE)					
From		To			
6	Inches	0	Feet	600	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NA	NA	NA	NA	NA

Perforations:  
Type of perforation N/A  
Size of perforation  
From ..... feet to ..... feet  
From ..... feet to ..... feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal NA  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From NA feet to ..... feet

9. WATER LEVEL  
Static water level Not Recorded feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Hydro Resources Nevada Inc., dba Humboldt Drilling & Pump Company, Inc.  
Contractor  
Address 4975 W. Winnemucca Blvd.  
Contractor  
Winnemucca, NV 89445  
Nevada contractor's license number issued by the State Contractor's Board 56797  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
Signed C. Jaynes - Office  
By (after performing actual drilling on site or contractor)  
Date 8/19/2006

Date started 6/21/2006 20 06  
Date completed 6/30/2006 20 06

7. WELL TEST DATA			
TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
NA	NA	NA	NA