COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101539
Permit No.
Basin 073

NOTICE OF INTENT NO. 58444

1. OWNER Ron Ward
MAILING ADDRESS 6230 Ingleston Drive #225
Sparks, NV 89436

ADDRESS AT WELL LOCATION Old Immigrant road
Lovelock, NV 89419

2. LOCATION ¼ Lot #1 ¼ Sec 30 T 28 N R 32 E Pershing County
PERMIT NO. SW NE (Issued by Water Resources) 003-311-19 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	30	30
Clay		30	50	20
Corse sand		50	75	25
Clay		75	110	35
Sand	x	110	115	5
Blue clay		115	145	30
Black corse sand	x	145	175	30

N 40°15.738'
W 118°25.463'
Elevation 4001
NAD 83

Date started June 11, 20 06
Date completed June 13, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		5

RECEIVED 2006 AUG 11 AM 11:45 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	175

Perforations:
Type perforation Factory cut
Size perforation 0.50
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 175 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the ~~on site driller~~ 2083
Signed
By driller performing actual drilling on site or contractor
Date July 17, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com