

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
 Log No. 101540
 Permit No. _____
 Basin 073
 NOTICE OF INTENT NO. 58441

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ron Ward
 MAILING ADDRESS 6230 Ingleston Drive #225 Sparks, NV 89436
 ADDRESS AT WELL LOCATION N. Meridian Road Lovelock, NV 89419

2. LOCATION NE 1/4 NE 1/4 Sec 34 T 28 N R 31 E Pershing County
 PERMIT NO. 003-151-66
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Brown clay		3	60	57
Blue clay w/ b. sand		60	100	40
Black sand		100	120	20
Blue clay		120	145	25
Brown sand, fine gravel	x	145	155	10
Blue clay		155	160	5
N 40° 15.143'				
W 118° 28.657'				
Elevation 3978 <u>NAD 83</u>				

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	160

Perforations:
 Type perforation Factory cut
 Size perforation 0.50
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 160 feet

9. WATER LEVEL

Static water level 45 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling, Inc.
 (CONTRACTOR)
 Address 10760 Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed _____
 By driller performing actual drilling on site or contractor
 Date July 7, 2006

Date started June 5, 20 06
 Date completed June 6, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Draw Down (Feet Below Static)			
Time (Hours)			<u>5</u>

STATE ENGINEERS OFFICE
 2006 AUG 11 AM 11:45
 RECEIVED