

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 101548
 Permit No. _____
 Basin Ø67

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56361

1. OWNER K 7 Construction Inc ADDRESS AT WELL LOCATION 5975 Home Gardens Dr
 MAILING ADDRESS P O Box 70205 Reno NV 89570

2. LOCATION SE NE Sec. 31 T. 19 N/S R. 20 E Washoe County
 PERMIT NO. 025-441-01 Home Gardens
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Well was abandoned				
8/4/2006				
Attempts to pull well casing failed				
Well was perforated from 125 to 3 ft				
A6 inch mills knife was used to perforat the well				
4 perforationper ft				
Al 1/4 inch pipe was set 128 ft and neat cement waspump to top of well				
well elev 4480 Ft				
N39.28.212				
W119.46.491				

8. WELL CONSTRUCTION
 Depth Drilled 128 Feet Depth Cased 128 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet 128 Feet
 _____ Inches Feet Feet
 _____ Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	10.5	1.88	0	128

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Knoblock & Sons Pump and Supply
 Contractor
 Address 5425 Spanish Moss
 Contractor
Sparks NV 89436
 Nevada contractor's license number issued by the State Contractor's Board. 49162
 Nevada driller's license number issued by the Division of Water Resources. the on-site driller. AB 2213
 Signed William J. Knoblock
 By driller performing actual drilling on site or contractor
 Date 8/8/2006

Date started 8/4/2006, 19____
 Date completed 8/4/2006, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 2006 AUG 16 AM 11:20
 STATE ENGINEERS OFFICE