COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101577
Permit No.
Basin 071

NOTICE OF INTENT NO. 58447

1. OWNER Ron Ward
MAILING ADDRESS 6230 Ingleston Drive #225
Sparks, NV 89436

ADDRESS AT WELL LOCATION West Fall Road
Lovelock, NV 89419

2. LOCATION NE ¼ Lot #7 ¼ Sec 17 T 26 N R 31 E Pershing County
PERMIT NO. 5E (Issued by Water Resources) | 007-411-15 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Clay		0	15	15
Corse Sand		15	45	30
Blue clay		45	60	15
Brownish, black clay		60	100	40
Blue Clay		100	130	30
Black sand	x	130	178	48

~~N 40°56.441'~~
~~W 117°41.466'~~
~~Elevation 5090~~

N 40° 07.314'
W 118° 30.883
elev 3940'
WGS 84

Date started June 15, 20 06
Date completed June 16, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		4

STATE ENGINEERS OFFICE
2006 AUG 11 AM 11:45
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 178 Feet Depth Cased 178 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	178 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	178

Perforations:
Type perforation Factory cut
Size perforation 0.50
From 158 feet to 178 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 178 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date July 17, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com