WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101608
Permit No.
Basin 067

NOTICE OF INTENT NO. 57801

1. OWNER Crystal Springs Water
MAILING ADDRESS 901 S. Center St.
Reno, NV 89502

ADDRESS AT WELL LOCATION 901 S.Center St. Reno

2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 19N N/S R 19E E Washoe County
PERMIT NO. MD-1019 Issued by Water Resources
11-334-15 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 2" x 13' Monitor well by pumping 1 cubic foot of neat cement mixed 5.2 gallons of water per sack. We pumped using tremie pipe from the bottom to the top.				
Monitor Well MW2				
NAD83				
N 39.51672				
W 119.80793				
OLD WELL LOG 52065				
39.516829 °N				
119.806924 °W				
NAD27 ConUS				

Date started 9/19/2006 , 19__
Date completed 9/19/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
2006 SEP 26 AM 10:43
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 13 Feet Depth Cased 13 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	13	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH40	0	13

Perforations:
Type perforation Screen
Size perforation .020
From 3 feet to 13 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 3 feet to 13 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 9/19/2006

USE ADDITIONAL SHEETS IF NECESSARY