

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 101680  
 Permit No. \_\_\_\_\_  
 Basin 103

NOTICE OF INTENT NO. 58276  
#7 Stacie Court

1. OWNER Monte Waite ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 30 T. 17N N/S R. 22 E 140d County \_\_\_\_\_  
 PERMIT NO. 019-241-23 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & Cobles		0	90	90
Black Rock		90	110	20
Black Rock		110		
Gravel			160	50
Clay & Gravel		160	175	15
Black & Gravel		175	260	95

39.31538° N  
 119.510420° W NAD 83

~~39.315483° N~~  
~~119.510420° W~~  
~~NAD 83~~

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 260 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>20</u>	<u>260</u>

Perforations:  
 Type perforation Grinder cut  
 Size perforation 18 a.s.b.  
 From 20 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Artesian flow N/A G.P.M. 157 P.S.I.  
 Water temperature cold °F Quality Clear

Date started 8-30, 2006  
 Date completed 8-31, 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>157</u>		<u>4 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING CONTRACTOR CO. INC.  
 Address P.O. Box 1255  
Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46499  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-01-06