


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 101688  
Permit No. ....  
Basin 084

NOTICE OF INTENT NO 58391

1. OWNER Inge Bonqartz - Thowald  
MAILING ADDRESS 6755 Quaking Aspen

ADDRESS AT WELL LOCATION 6600 Quaking Aspen  
Latitude N 39.43.188  
Longitude W 119.30.761  
WGS 84

2. Location NE 1/4 NE 1/4 Sec 4 T 21 N R 22 E Washoe County  
PERMIT NO. PARCEL NO. 077250-007 SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel + Boulders	x	0	40	40
Sand + Gravel		40	75	35
Clay + Gravel		75	105	30
Sand + Gravel		105	220	115
Clay + Gravel		220	240	20
Sand + Gravel	x	240	260	20
Clay		260	275	15
Sand + Gravel	x	275	297	22

8. WELL CONSTRUCTION

Depth Drilled		Depth Cased	
297 feet		297 feet	

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 inches	0 feet	100 feet
8 3/4 inches	100 feet	297 feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	297

Perforations:

Type Perforation	Factory
Size perforation	3/32 x 3"
From 297 feet to 277 feet	
From 237 feet to 257 feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
Surface Seal	X YES No
Depth of Seal	100 feet
	x Pumped
	Poured
Gravel Packed:	x Yes No
From 297 feet to 100 feet	

Seal Type:  
Neat Cement  
X Cement Grout  
Concrete Grout

39.719910°N 119.511683°W  
NAD27 Gm US

RECEIVED  
2006 OCT -2 AM 11:20  
STATE ENGINEERS OFFICE

9. WATER LEVEL

Static water level	20 feet below land surface
Artesian flow	0 GPM 0 P.S.I.
Water Temperature	cold Degrees F Quality good

Date started 8-9 -06  
Date completed 8-17 -06

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
12	297	2		
7	240	1		
4	180	1		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.  
2290 Pioneer Drive  
Reno, NV 89509

NV Contractors No. 14170  
NV Driller's Lic (on site) 2292

Signed

By driller performing actual drilling on site or contractor  
Date 8-22 -06