


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 101725  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **30400**

1. OWNER **MARIA RODRIGUEZ**  
 MAILING ADDRESS **5801 E DOUBLETREE RD**  
**PAHRUMP, NV**

ADDRESS AT WELL LOCATION **5801 E DOUBLETREE RD**

2. LOCATION NE 1/4 SE 1/4 Sec. 16 T 21S  
 PERMIT NO. 43-101-03  
Issued by Water Resources Parcel No.

N/S R 54E E NYE County  
**COTTONWOODS**  
Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT & ROCK		0	15	15
CLAY & ROCK		15	75	60
GRAVEL	WB	75	87	12
CLAY & ROCK		87	115	28
SAND & GRAVEL	WB	115	130	15
CLAY & GRAVEL		130	150	20
SAND & GRAVEL	WB	150	170	20
CLAY & GRAVEL		170	180	10

DCNR/DWR  
RECEIVED

NOV 22 2006

LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 inches To 0 Feet 180 Feet  
inches Feet Feet  
inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:  
 Type perforation **SAWCUT**  
 Size perforation **1/8 X 3**

From	<u>80</u> feet to	<u>100</u> feet
From	<u>120</u> feet to	<u>140</u> feet
From	<u>160</u> feet to	<u>180</u> feet
From	feet to	feet
From	feet to	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout


Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 78 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11/16/2006 19  
 Date completed 11/17/2006 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **1220 E MANSE RD** Contractor  
**PAHRUMP, NV, 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**  
 Signed   
 By driller performing actual drilling on-site or contractor  
 Date **11/17/2006**