


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 101736
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30788

1. OWNER PANORAMA TOWERS III LLC ADDRESS AT WELL LOCATION 4471 DEAN MARTIN DR
 MAILING ADDRESS 4230 S DECATUR #B LAS VEGAS, NV 89103
LAS VEGAS, NV 89103

2. LOCATION SE 1/4 NW 1/4 Sec 20 T 20 S R 61 E CLARK County

PERMIT NO. DW1224 162-20-210-014 2104
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
4-Dewatering wells				
Brown dirt caliche		0	7	
Sandy silt & rock		7	18	
White clay & rock		18	30	
Brown clay		30	37'	
White clay & rock		37	40'	
Brown clay		40	47'	
Brown clay		47	50'	

DCNR/DWR
 RECEIVED
 NOV 22 2006
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24 Inches 0 Feet 50 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"	36-71	.250		

Perforations:
 Type perforation Machine
 Size perforation 1/4" X 2.5" long 16 around
 From 10 feet to 50 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 30 feet

9. WATER LEVEL
 Static water level 11 feet below land surface
 Artesian flow no G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 11/16, 20 06
 Date completed 11/17, 20 06

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC.

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Address 4015 West Tompkins Ave.
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. ABDS2161
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/17/06