

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29825

1. OWNER Pebble Road LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5495 S. Rainbow Blvd. 202 pebble Rd.
LV NV 89118
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T 22 N15 R 10 E Clark County
 PERMIT NO. 17618-401-019 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + gravel		0	275	275
SANDSTONE	X	275	450	175
SANDSTONE WITH CLAYSTONE	X	450	540	90

OCNR/DWR RECEIVED
 NOV 22 2006
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 540 Feet Depth Cased 530 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 540 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>F480</u>	<u>1/4</u>	<u>+1</u>	<u>530</u>
<u>8 5/8"</u>	<u>188</u>		<u>1</u>	<u>4'</u>

Perforations:
 Type perforation SAW
 Size perforation 1/8 x 6
 From 460 feet to 520 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50+ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 530 feet

9. WATER LEVEL
 Static water level 433 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Redding Drilling Contractor
 Address 530 E. Larson Ln Henderson NV 89044 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 38155
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
 Signed Floyd Mitchell
 By driller performing actual drilling on site or contractor
 Date 11-20-06

Date started 10-18- 2006
 Date completed 10-31- 2006

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>40+</u>		<u>2 hrs</u>	