

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 101778
Permit No. _____
Basin 212



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30437

1 OWNER CC Parks & Community Services ADDRESS-AT WELL LOCATION 210 Via Antincendio
MAILING ADDRESS 2601 East Sunset Road Henderson, NV 89015
Las Vegas, NV 89120 Subdivision Name: Powerline Weir Crossing 3.3 County: Clark

2 LOCATION SW ¼ SE ¼ Sec 21 T 21S N/S R 63 E Latitude See Attached UTM E NAD 27
PERMIT/WAIVER No. dw-1214 160-21-810-032 Longitude N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Dewater Is this well being plugged because a replacement well was drilled? no Is there an existing well log? _____
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock If yes, what is replacement well NO? _____ If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 49 Feet Depth Cased 49 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	5.7	.332	0	49

Existing Perforations:

From	Type of perforation	Size of perforation	feet to	feet

5 WATER LEVEL
Static water level 10 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality _____

6 Additional Notes or Comments
This is wells 15 and 16. These are the only 2 dewatering wells on this parcel.

DCNR/DWR RECEIVED
DEC 04 2006

LAS VEGAS OFFICE

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: _____

From	feet to	feet	Number of perfs per linear foot

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 10 feet neat cement Pumped Poured
From _____ feet to _____ feet Pumped Poured

Neat Cement Fluid Weight 96/6 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 9/27/2006
Date Completed 9/27/2006

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc. Contractor
Address 801 Northport Dr. Contractor
West Sacramento, CA 95691
Nevada contractor's license number issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-2091
Signed _____
Date 10/10/2006

USE ADDITIONAL SHEETS IF NECESSARY