39 30.617 N / 118 53.015 W WGS 84

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

I

OFFICE USE ONLY
Log No. 101961
Permit No.
Basin 101

NOTICE OF INTENT NO. 56191

1. OWNER Joan
MAILING ADDRESS 6412 Lake View
ADDRESS AT WELL LOCATION 6412 Lake View Dr

2. LOCATION NW ¼ SE ¼ Sec. 18 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 008-113-23 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blonde Sand		0	4	
Black Sand		4	6	
Blond Sand		6	26	
Clay (Brown)		29	65	
Black Clay		65	162	
Black Sand		162	283	
(Some Clay)		283		
Clay Grey		283	315	
Brown Sands		315	340	
& Gravels				
Black Clay		340	349	
Grey Sands		349	364	
Brown Clay		364	371	
Brown Sand, fine		371	380	
Grey Black Sands		380	413	
Grey Clay		413	418	
Brown Gravels				
Sands		418	439	
Grey Clay		439	440	
39.510384 °N				
118.882603 °W				
NAD27				

Date started Dec 11, 06, 20
Date complated Dec 15 06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		3½ hrs

STATE ENGINEERS OFFICE
2006 DEC 29 PM 2:12
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	440 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1.88	13	1	440

Perforations:
Type perforation 1/8 mill pvf
Size perforation 1/8 / 2½ x 8# rows pvf
From 420 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 440' feet

9. WATER LEVEL
Static water level 19' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pearson Drilling Inc
Contractor
Address P.O. Box 599
Contractor
SS, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature]
By driller performing actual drilling on site or contractor
Date Dec 21 06

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627