REPORT NO. A06.071

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 101970
PERMIT NO.
BASIN 083

NOTICE OF INTENT NO. 57557

1. OWNER Mark Green
MAILING ADDRESS 9350 Oakley Ct, Reno NV 89521

ADDRESS OF WELL 1550 Yellowjacket Rd
Reno, NV 89521

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 31 T 18N R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 003-461-45 SUBDIVISION NAME Highland Ranches

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Top Soil		0	5	5
Black & White Rock		5	15	10
Yellow Clay		15	35	20
Yellow Clay & White Rock		35	115	80
Yellow Clay		115	130	15
Black/White Clay & Rock		130	190	60
Green & Black Rock		190	215	25
Black & White Rock		215	225	10
Black & Green Rock		225	230	5
Black Rock & Clay		230	250	20
Black & White Rock		250	270	20
Black Rock & Clay		270	280	10
Black & Green Rock		280	370	90
Gray Rock		370	445	75
Black & Green Rock		445	475	30
Gray Rock		475	615	140
Gray & Black Rock		615	655	40
Gray Rock & Gray Clay		655	800	145
Gray Rock		800	815	15
Gray & Red Rock		815	955	140

Notes: WGS-84 GPS: Latitude: N39 23.150 Longtitude: W119 40.273
Report continued on to Report # A06.072

39.385939N 119.670217W NAD27

Date Started 06/12/2006 Date Completed 10/02/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	3		

8. WELL CONSTRUCTION

Depth Drilled 1456 Depth Cased 1456

HOLE DIAMETER (BIT SIZE)

10 5/8	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	770	Feet
6 1/4	Inches	770	Feet	1456	Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	770
5	9.66	.188	720	1456

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32x3
From 1236 Feet to 1276 Feet
From 1376 Feet to 1436 Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 770 Feet

9. WATER LEVEL
Static Water Level 800 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2275

Signed Roger m Thrall
By driller performing actual drilling on site or contractor

Dated October 26-2006

REPORT NO. A06.072

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO.
PERMIT NO.
BASIN Ø83

NOTICE OF INTENT NO. 57557

1. OWNER Mark Green
MAILING ADDRESS 9350 Oakley Ct, Reno NV 89521

ADDRESS OF WELL 1550 Yellowjacket Rd
Reno, NV 89521

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 31 T 18N R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 003-461-45 SUBDIVISION NAME Highland Ranches

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Gray & White Rock		955	970	15
Multicolored Rock		970	1015	45
Gray Rock Hard		1015	1085	70
Gray Clay		1085	1170	85
Gray Rock & Clay		1170	1230	60
Gray Clay		1230	1265	35
Green & Gray Rock		1265	1360	95
Black Rock		1360	1405	45
Black Rock & Clay		1405	1445	40
Gray Rock		1445	1456	11

Notes : WGS-84 GPS: Latitude: N39 23.150' Longtitude: W119 40.273
Report continued from Report # A06.071

Date Started 06/12/2006 Date Completed 10/02/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	3		

8. WELL CONSTRUCTION
Depth Drilled 1456 Depth Cased 1456

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 770 Feet
6 1/4 Inches 770 Feet 1456 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
5"	9.66	.188	720'	1456'
6 5/8"	12.92	.188	+2	770'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32x3
From 1236 Feet to 1276 Feet
From 1376 Feet to 1436 Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 770 Feet

9. WATER LEVEL
Static Water Level 800 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2275

Signed Roger m Thrall
By driller performing actual drilling on site or contractor

Dated October 26 2006