

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 101984  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30343  
 ADDRESS AT WELL LOCATION 3698 S. LAS VEGAS BLVD.  
LAS VEGAS, NV

1. OWNER 3700 ASSOCIATES LLC  
 MAILING ADDRESS 667 MADISON AVE  
NEW YORK, NY 10021-8029

2. LOCATION SW 1/4 NE 1/4 Sec 20 T 21 S R 61 E CLARK County

PERMIT NO. DW1220B 162-20-603-007  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Dewater

4. PROPOSED USE Dewater  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>4-80' Dewatering wells</b>				
Asphalt		0'	3"	
Brown aluvium		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt		14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	5'
Caliche		26'	31'	5'
Red clay		31'	33'	2'
Brown clay		33'	38'	5'
White silty clay		38'	48'	10'
Brown clay small rock		48'	51'	3'
Caliche		51'	55'	4'
Red clay		55'	68'	8'
White clay		68'	80'	12'

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>24"</u> Inches	<u>0</u> Feet <u>80</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation Machine  
 Size perforation .25"x2.5x3 rows @13  
 From 35 feet to 80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 80 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11/7, 20 06  
 Date completed 11/14, 20 06

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static) Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231  
 Signed Vitez Allen  
 By driller performing actual drilling on site or contractor  
 Date 12/8/06