COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101987
Permit No.
Basin 212

NOTICE OF INTENT NO. 30343

1. OWNER 3700 ASSOCIATES LLC
MAILING ADDRESS 667 MADISON AVE
NEW YORK, NY 10021-8029

ADDRESS AT WELL LOCATION 3698 S. LAS VEGAS BLVD.
LAS VEGAS, NV

2. LOCATION SW ¼ NE ¼ Sec 20 T 21 S R 61 E CLARK County

PERMIT NO. DW1220B (Issued by Water Resources) | 162-20-603-007 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1-Dewatering wells				
Asphalt		0'	3"	
Brown aluvium		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt		14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	5'
Caliche		26'	31'	5'
Red clay		31'	33'	2'
Brown clay		33'	38'	5'
White silty clay		38'	45'	10'
Brown clay small rock		45'	51'	3'
Caliche		51'	55'	4'

DCNR/DWR
RECEIVED
DEC 26 2006
LAS VEGAS OFFICE

Date started 11/14, 20 06
Date completed 11/14, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24" Inches	0 Feet	55 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation .25"x2.5x3 rows @13
From 55 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 55 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed [signature]
By driller performing actual drilling on site or contractor
Date 12/8/06

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com