AMENDED AS OF 8/7/07

COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102036
Permit No.
Basin 212

NOTICE OF INTENT NO. **30793**

1. OWNER **S B H LOT OPTION LLC**
MAILING ADDRESS **5502 NE 44TH ST**
VANCOUVER, WA 98661-3280

ADDRESS AT WELL LOCATION **AGATE AVE**

2. LOCATION **NW** ¼ **NW** ¼ Sec **22** T **22** S R **60** E **CLARK** County

PERMIT NO. (Issued by Water Resources) | Parcel No. **176-22-101-048** | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug 1 domestic well				
Depth 644'				
casing 8 5/8" steel				
Static water level 504'				
perforation from 644' to				
400' with air perforator				
Trimmie 6 yards of W171				
slurry and let harden.				
measured next day,				
cement @ 253'. Free fall				
9 sac grout from 253' to				
surface.				

DCNR/DWR RECEIVED AUG 09 2007 LAS VEGAS OFFICE

Date started **11/30**, 20 **06**
Date completed **12/11**, 20 **06**

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **ALLEN DRILLING INC.** (CONTRACTOR)
Address **4015 West Tompkins Ave.** (CONTRACTOR)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board **18916 & 18917**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1301**
Signed Fred G. Allen II
By driller performing actual drilling on site or contractor
Date **(REVISED) 8/7/07**

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com