WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESO[redacted]

WELL DRILLER'S REP[redacted]

Please complete this form in its entirety [redacted] accordance with NRS 534.170 and NAC 534.340

[redacted]FICE USE ONLY
[redacted]2069
[redacted]662

NOTICE OF INTENT NO. 30482

1. OWNER BEAZER HOMES
MAILING ADDRESS 5651 S SQUAW VALLEY RD
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5651 S SQUAW VALLEY RD

2. LOCATION NW 1/4 SW 1/4 Sec. 8 T 21S N/S R 54E E NYE County
PERMIT NO. (Issued by Water Resources) 45-081-13 Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PERF WELL FROM 400 TO 65				
HIT CEMENT SEAL WITH PERFORATER @ 65'				
PUMP BENTONITE GROUT FROM 400 TO 70FT. PUMP NEAT CEMENT FROM 70FT TO SURFACE				

DCNR/DWR
RECEIVED
JAN 09 2007
LAS VEGAS OFFICE

Date started 1/2/2006 , 19__
Date completed 1/2/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased EXISTING Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EXISTING	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"			0	400

Perforations:
Type perforation HOLTZ AIR PERFORATOR
Size perforation 1/4 X 1 1/2
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal EXISTING
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ___ feet to ___ feet

9. WATER LEVEL
Static water level ___ feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature ___ °F Quality ___

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed ___ (By driller performing actual drilling on-site or contractor)
Date 1/4/2007

USE ADDITIONAL SHEETS IF NECESSARY