WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102076
Permit No.
Basin 212

NOTICE OF INTENT NO. 30878

1. OWNER M. Holdings LLC 222 Via Marnell Way, Las Vegas NV
MAILING ADDRESS
ADDRESS AT WELL LOCATION 12439 Giles Ave, Las Vegas NV

2. LOCATION SW ¼ NW ¼ Sec. 09 T. 23 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) | Parcel No. 191-09-201-016 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled system from well. Abandoned 8" well to 444' Depth. Existing perforations from 444' to 400' Perforated casing from 400' to 386' Pumped 5-5 yards of neat cement from the bottom of the well through a tremmie line to the surface which completely filled the well.				

PLUGGED BY GWMP
ORIG/PLUG LOG # 53463

DCNR/DWR
RECEIVED
JAN 11 2007
LAS VEGAS OFFICE

Date started 1/4/, 2007
Date completed 1/8/, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 444 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 336' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling (Contractor)
Address 2870 W Pebble Rd (Contractor)
Las Vegas NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2333-T1
Signed Alex Segura (By driller performing actual drilling on site or contractor)
Date 1/10/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627