WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102097
Permit No. 46320
Basin 162

NOTICE OF INTENT NO. 29795

1. OWNER Utilities Inc.
MAILING ADDRESS PO Box 730 Pahrump NV.
ADDRESS AT WELL LOCATION 3971 E. Winery rd Pahrump NV.

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 20 N/S R. 54 E. NYE County
PERMIT NO. 46320 Issued by Water Resources | 4286309 Parcel No. | Calvada Valley Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well has a 60' sanitary seal				
Well is clean of debris 500', Mill Knife casing 4 times per ft. From top of perforations at 292' up to 130'				
Dug down around casing 6', installed tremie pipe to bottom of well, pumped well full from bottom to top, cut off casing at 6' below ground level + made cement cap over casing let cement set up then back fill hole				
PLUGGED BY GWMP ORIG/ PLUG LOG # 27617				
DCNR/DWR RECEIVED JAN 04 2007 LAS VEGAS OFFICE				

Date started 20 December, 2006
Date completed 22 December, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

Perforations:
Type perforation Mill Slot
Size perforation
From 292' feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 500'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 192' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Co. (Contractor)
Address PO Box 1249 (Contractor)
Barstow CA 92312
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2324
Signed Marty Garrison (By driller performing actual drilling on site or contractor)
Date 22 December 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627