

003601N  
PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

*6wells*

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30667

1. OWNER ROSE PELINO ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 6 SYLVAN WAY 5164 RENT-A-CAR RD.  
PARSONS NJ LAS VEGAS NV  
2. LOCATION SE 1/4 NW 1/4 Sec 07 T 21 N/S R 61 E CLARK County  
PERMIT NO. 162-27-201-005 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other MSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0.0</u>	<u>0.4</u>	<u>0.4</u>
<u>SAND W/ GRAVEL</u>		<u>0.4</u>	<u>5.0</u>	<u>4.6</u>
<u>CLAYEY SAND</u>		<u>5.0</u>	<u>10.0</u>	<u>5.0</u>
<u>CHALK</u>		<u>10.0</u>	<u>18.0</u>	<u>8.0</u>
<u>SILTY CLAY</u>		<u>18.0</u>	<u>25.0</u>	<u>7.0</u>
<u>CHALK</u>		<u>25.0</u>	<u>28.0</u>	<u>3.0</u>
<u>CLAY / SILTY CLAY</u>		<u>28.0</u>	<u>45.0</u>	<u>17.0</u>
<u>MAP DATUM</u>				
<u>WGS 84</u>				
<u>36° 05' 9.62" N 115° 09' 76.2" W</u>				
<u>36° 05' 8.34" N 115° 09' 96.8" W</u>				
<u>36° 05' 8.28" N 115° 09' 95.6" W</u>				
<u>36° 05' 8.41" N 115° 09' 73.2" W</u>				
<u>36° 05' 8.11" N 115° 09' 02.2" W</u>				
<u>36° 05' 8.42" N 115° 09' 02.4" W</u>				

8. WELL CONSTRUCTION  
Depth Drilled 45/30 Feet Depth Cased 45/30 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
8 1/2 Inches 0.0 Feet 45.0 Feet  
8 1/2 Inches 0.0 Feet 30.0 Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2.0 5440 PVL 0.0 45.0  
2.0 5490 PVL 0.0 30.0

Perforations:  
Type perforation MACHINER SUE T  
Size perforation 0.20  
From 45.0 feet to 40.0 feet  
From 30.0 feet to 10.0 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 1'  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 45/30 feet to 38/8 feet

9. WATER LEVEL  
Static water level 18 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EMME DRILLING SERVICES LLC Contractor  
Address 7150 PLACID ST Contractor  
LAS VEGAS NV 89119  
Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 01/11/07

Date started 12/19, 2006  
Date completed 12/28, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			