MW-6 Coor. N 39° 30.341
W 119° 48.395

Plugged by Well Log # 110635

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10d1416
Permit No.
Basin 087

NOTICE OF INTENT NO. 55477

1. OWNER Conoco phillips co.
MAILING ADDRESS 1230 W. washington ST. Suite 212 Tempe, Az. 85281
ADDRESS AT WELL LOCATION between 160 + 190 W Plumb Ln. Reno, NV. 89509

2. LOCATION NW ¼ NW ¼ Sec. 24 T 19 N S R 19 E washoe County
PERMIT NO. 4-000419 NDEP (Issued by Water Resources) | 019-051-01 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, Sand, clay cobbles		0'	28'	28'
Silt, sand, clay, cobbles	Wet	28'	45'	17'
39.505772N				
119.805559W NAD27				
GPS: N 39° 30.341' W 119° 48.395'				
Datum = NAD 83				

Date started 11-1, 2006
Date completed 11-1, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45' Feet Depth Cased 45' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	40	.237	30'	0'

Perforations:
Type perforation factory
Size perforation .020
From 45' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 28'
Placement Method: ☒ Pumped N. cement 26-0 ☒ Poured 3/8 chips 28-26
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 45 feet to 28 feet

9. WATER LEVEL
Static water level 29.09 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear co. (Contractor)
Address 7773 W Seldon Ln. (Contractor)
Peoria, AZ. 85345
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2250
Signed Dennis R Reed (By driller performing actual drilling on site or contractor)
Date 11-3-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627