

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 102154  
 Permit No. \_\_\_\_\_  
 Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **58452**

1. OWNER **Charles Brown** ADDRESS AT WELL LOCATION **9575 Sabin**  
 MAILING ADDRESS **45 Nives Court Sparks, Nv 89441** **Winnemucca, NV 89445**  
 Subdivision Name: **Tycanna** County: **Humboldt**

2. LOCATION NE 1/4 SE 1/4 Sec 30 T 35 N R 38 E Latitude **N40°52.724** UTM E \_\_\_\_\_  NAD 27  
 PERMIT/WAIVER NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Longitude **W117°44.345** N \_\_\_\_\_  NAD 83/WGS 84  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Cobles		0	30	30
Boulders		30	50	20
Gravel & Cobles		50	240	190
Clay		240	280	40
Cobles		280	300	20
Clay		300	320	20
Sand & Gravel	X	320	350	30
Clay		350	360	10

40.878829 N  
 117.738121 W NAD27

2006 NOV 13 PM 2:38  
 STATE ENGINEERING DEPT

9. WELL CONSTRUCTION  
 Depth Drilled **360** Feet Depth Cased **360** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**105/8** Inches **0** Feet **360** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>65/8</b>	<b>10</b>	<b>1.88</b>	<b>+1</b>	<b>20</b>
<b>6.625</b>	<b>4.06</b>	<b>.316</b>	<b>20</b>	<b>360</b>

Perforations:  
 Type of perforation **Factory Cut**  
 Size of perforation **0501**  
 From **320** feet to **360** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 50  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No 50 to 360  Pumped  Poured  
 Type: **3/8**  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **Oct 30, 20 06**  
 Date completed: **Nov 3, 20 06**

7. Water Level  
 Static water level: **272** feet below land surface  
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.  
 Water Temperature: **Cool** °F  
 Quality: **Fair**

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.	<b>15</b>		<b>12</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.**  
 (CONTRACTOR)  
 Address **10760 S Grass Valley Rd.**  
 (CONTRACTOR)  
**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **21467**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**  
 Signed *Fred Anderson*  
 By driller performing actual drilling on site or contractor  
 Date **11-10-06**