



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. SP107

1. OWNER Frowk 101000 ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION NE 1/4 NE 1/4 Sec. 12 T. 12 N/S R. 20 E Douglas County  
PERMIT NO. 1220-1250-007 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT-GRAVEL		0	8	8
FRAC ROCK		8	66	58
BROWN CLAY		66	76	10
BROWN CLAY-ROCK		76	141	65
GRITTY BROWN CLAY	<del>X</del>	141	367	226
BROWN CLAY-FINE GRAVEL	<del>X</del>	367	400	33

38.92436° N  
119.67737° W NAD83

RECEIVED  
2006 NOV 28 PM 12:42  
STATE ENGINEERS OFFICE

38.924452 N  
119.676363 W  
NAD 27

8. WELL CONSTRUCTION  
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	0	50	Feet
<u>9 1/8</u>	50	400	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 3/8</u>	<u>4</u>	<u>SDR 21</u>	<u>20</u>	<u>400</u>

Perforations:

Type perforation GRINDER CUT  
Size perforation 1.045" x 4"

From	feet to	feet
<u>220</u>	<u>240</u>	feet
<u>260</u>	<u>280</u>	feet
<u>300</u>	<u>320</u>	feet
<u>340</u>	<u>360</u>	feet
<u>380</u>	<u>400</u>	feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 51 ft  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 51 feet to 400 feet

9. WATER LEVEL  
Static water level 125 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD F Quality CLEAR

Date started 23 OCT, 2006  
Date completed 27 OCT, 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO., INC.  
Address P.O. Box 1255 Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167

Signed Jack Dotson  
By driller performing actual drilling on site or contractor  
Date 25 Nov 06