WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102178
Permit No.
Basin 103

NOTICE OF INTENT NO. ~~[illegible]~~ 58065

1. OWNER R&B Homes
MAILING ADDRESS 1380 Greg St.
Sparks, NV 89431

ADDRESS AT WELL LOCATION 1/4 mile south of US Hwy 50 and Kelsey Court, Dayton NV.

2. LOCATION SE 1/4 NW 1/4 Sec. 33 T 17N N/S R 22E E Lyon County
PERMIT NO. 29011 2 (Issued by Water Resources) Parcel No. River Park (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to site and removed 105' of 3" drop pipe with a 5hp submersible pump from 8" well. Measured static water level at 51' and depth of well at 270'. installed 2" tremme pipe and blew debris from well to a depth of 280' where we hit a hard bottom. We then installed 8" Mills Knife and slotted 4 rows per foot from 240' back to 41' where it was difficult to perf because of cement seal. We then installed 273' of 2" tremme pipe and the following day we pumped in 6 yards of neat cement from the bottom of the well to the surface. GPS-39°17.813 north & 119°31.267 west, Elevation 4345'				
39.296987 N				
119.520122 W NAD27				

Date started 11/6/2006, 19__
Date completed 11/7/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	+1	280'

Perforations:
Type perforation Mills Knife
Size perforation
From 240' feet to 40' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 280'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 51.3' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Don Frangie (By driller performing actual drilling on-site or contractor)
Date 11/20/2006

USE ADDITIONAL SHEETS IF NECESSARY