STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

OFFICE USE ONLY
Log No. 102180
Permit No.
Basin 179

NOTICE OF INTENT NO. 58918

1. OWNER JOHN STINSON
MAILING ADDRESS P.O. BOX 150245
ELY, NV 89315

ADDRESS AT WELL LOCATION NORTH 151 STREET EAST STREET
Subdivision Name: County: WHITE PINE

2. LOCATION SE ¼ ¼ Sec 6 T 17N N/S R 64 E
PERMIT/WAIVER No. 010-310-04
Issued by Water Resources Parcel No.

Latitude 39.36294N
Longitude 114.80662W
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
HARDPAN		8	16	8
CEMENTED GRAVEL		16	40	24
HARDPAN		40	94	54
SAND & GRAVEL	X	94	120	26

RECEIVED 2006 NOV 22 AM 10:55 STATE ENGINEERS OFFICE

Date started: 9-Nov , 20 06
Date completed: 17-Nov , 20 06

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-17	20	120

Perforations:
Type of perforation SCREEN
Size of perforation 0.032
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 58 ☒ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 58 to 120 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 35 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	100	NA	16

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site or contractor)
Date 11-20-06

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY