REPORT NO. A06.081

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

I

LOG NO. 102188
PERMIT NO.
BASIN Ø93

NOTICE OF INTENT NO. 57154

1. OWNER Brian & Sam Dimuzio
MAILING ADDRESS 670 Queens Way, Sparks NV 89431

ADDRESS OF WELL 40 Snow Lane
Antelope Valley, NV

2. WELL LOCATION SW 1/4 NE 1/4 SEC. 15 T 22 R 19 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 79-490-18 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Sand		0	5	5
DG		5	50	45
DG & Clay		50	135	85
Boulders & DG		135	210	75
Green Granite & DG		210	310	100
Green & White Rock		310	365	55
Green & White Rock & DG		365	415	50
Hard Rock		415	435	20
Broken Up Rock		435	460	25
Hard Rock		460	540	80
Hard Multi Colored Rock		540	560	20
Broken Up Rock		560	598	38

2006 NOV 20 PM 12:58

Notes : WGS-84 GPS: Latitude: N39 46.615 Longtitude: W119 50.159

39.777030 N
119.834973 W NAD27

Date Started 10/10/2006 Date Completed 10/20/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		3

8. WELL CONSTRUCTION

Depth Drilled 598' Depth Cased 598'

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 60 Feet
8 1/2 Inches 60 Feet 538 Feet
6 Inches 538 Feet 598 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+2	538'
5"	9.66	.188	518'	598'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 518 Feet to 538 Feet
From 558 Feet to 598 Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 538 Feet

9. WATER LEVEL
Static Water Level 480 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2275

Signed [signature]
By driller performing actual drilling on site or contractor

Dated Nov 17, 2006