


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 102192
Permit No. _____
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59011

1. OWNER B&B INVESTMENTS ADDRESS AT WELL LOCATION NE CORNER OF CHUCKER & MARSHA
MAILING ADDRESS P. O. BOX 1900, ELKO, NV 89803
Subdivision Name: LUCKY NUGGET #1 County: ELKO

2. LOCATION SW ¼ SE ¼ Sec 23 T 32N N/S R 55 E Latitude _____ UTM E 11T 0605972 NAD 27
PERMIT/WAIVER No. _____ 027-050-004 Longitude _____ N 4499558 NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	15	15
COARSE GRAVEL		15	45	30
GRAVEL/ SOME CLAY		45	55	10
GRAY CLAY w/ SOME GRAVEL		55	165	110
FINE GRAVEL	X	165	200	35
TAN CLAY & GRAVEL		200	205	5
GRAVEL	XX	205	240	35
<u>40.640165 N</u>				
<u>115.745853 W NAD27</u>				

9. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>240</u>	<u>240</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.</u>	<u>.188</u>	<u>+2</u>	<u>240</u>

Perforations:

Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3", 6 ROW

From 220 feet to 240 feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 10 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 50 to 240 Pumped Poured
Type: 3/8" WASHED PEA GRAVEL

Bentonite Chips: Yes No 10 to 50 Pumped Poured
Type: 3/8" MEDIUM CHIP

Date started: 9-Oct , 20 06
Date completed: 10-Oct , 20 06

7. Water Level
Static water level: 133 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>3</u>	<u>3</u>
<u>50</u>	<u>20</u>	<u>20</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING INC
Contractor

Address P. O. BOX 850
Contractor

ELKO, NV 89803

Nevada contractor's license number _____
issued by the State Contractor's Board 020582

Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 1166

Signed Dale C. Winters
By driller performing actual drilling on site or contractor

Date 12-Oct-06