STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 102206
Permit No.
Basin 076

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58331

1. OWNER C-PUNCH
MAILING ADDRESS 10 McDougal
Lovelock, NV 89419

ADDRESS AT WELL LOCATION Granite Springs Valley
40.08312 118.91832 NAD 27

2. LOCATION NE ¼ NW ¼ Sec 35 T 26N N/S R 27 E
PERMIT/WAIVER No. _____ Issued by Water Resources _____ Parcel No.

Latitude 40°4.9871
Longitude 118°55.0993
UTM E _____ N _____
☒ NAD 27 ☐ NAD 83/WGS 84
Subdivision Name: County: Pershing

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	7	7
Decomposed Granite		7	14	7
CLAY		14	21	7
Decomposed Granite		21	160	139
CLAY & SAND		160	200	40
Decomposed Granite		200	340	140
SAND & CLAY		340	375	35
Decomposed Granite		375	430	55
CLAY		430	440	10

Date started 16-Oct , 20 06
Date completed 19-Oct , 20 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PWL=253	300	22	4 hr

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	420	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		188	+2	420

Perforations:
Type of perforation MILL SLOT
Size of perforation 0.09
From 220 feet to 420 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 231 feet below land surface
Artesian flow NO G.P.M _____ P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada, Inc. dba Humboldt Drilling & Pump (Contractor)
Address 4975 W. Winnemucca Blvd. Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2099
Signed Judi Leach Office (By driller performing actual drilling on site of contractor)
Date 11/13/2006

STATE ENGINEER'S OFFICE
2006 NOV 16 AM 11:26
RECEIVED

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY