

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 102209  
 Permit No. 72172  
 Basin 033B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55662**

1. OWNER **Quinn River Baptist Church** ADDRESS AT WELL LOCATION **US 95 South**  
 MAILING ADDRESS **PO Box 337 McDermitt, NV 89421** **McDermitt, NV 89421**

Subdivision Name: \_\_\_\_\_ County: **Humboldt**  
 2. LOCATION SW 1/4 NW 1/4 Sec 9 T47 N N/S R38 E Latitude **41°58.425** UTM E \_\_\_\_\_  NAD 27  
 PERMIT/WAIVER NO. 72172 **003-162-04** Longitude **117°42.782** N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Other  
 4. PROPOSED USE  Domestic  Irrigation  Test  Monitor  Stock  Municipal/Industrial  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/Clay		0	4	4
Rock		4	10	6
Clay brown		10	13	7
Rock w/sand		13	40	27
cobles		40	45	5
course gravel & sand		45	80	35
clay		80	85	5
sand & gravel	x	85	145	60
clay sand		145	150	6
course sand & gravel	x	150	190	40
clay		190	200	10

9. WELL CONSTRUCTION  
 Depth Drilled **200** Feet Depth Cased **200** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**10 5/8** Inches **0** Feet **200** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	+1	20
6.625	4.06	.316	20	200

Perforations:  
 Type of perforation **Factory Cut**  
 Size of perforation **050**  
 From **160** feet to **200** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 57  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No 57 to 200  Pumped  Poured  
 Type: **3/8**  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **November 10, 20 06**  
 Date completed: **November 14, 20 06**

7. Water Level  
 Static water level: **17** feet below land surface  
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.  
 Water Temperature: **cool** °F  
 Quality: **fair**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.**  
(CONTRACTOR)

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.			
<b>15</b>			<b>5</b>

Address **10760 S. Grass Valley Rd**  
(CONTRACTOR)  
**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **21467**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller, **2083**  
 Signed *Fred Anderson*  
 By driller performing actual drilling on site or contractor  
 Date **November 15, 2006**